



Date: October 13, 2021

Project: Nunapitchuk Construction

Solicitation No.: 22012

Addendum No. Three

TO ALL PLANHOLDERS:

The enclosed addendum amends the bid documents for the above referenced Project.

Acknowledgment of this addendum is required on the Proposal Form. Failure to do so may subject the bidder to disqualification.

Sincerely,

DocuSigned by:
Selwin C. Ray
0A1919DCB4834AC...

Selwin C. Ray
Contracting Officer

ADDENDUM TO CONTRACT DOCUMENTS	Page Number 1	No. of Pages 2
Addendum No. THREE	Date Addendum Issued: October 13, 2021	
Issuing Office Selwin Ray Alaska Energy Authority 813 W Northern Lights Blvd Anchorage, AK 99503 Phone: (907) 771-3035 Fax: (907) 771-3044	Previous Addenda Issued TWO	
Project: Nunapitchuk Construction Procurement Solicitation No.: 22012	Date and Hour Bids Due: October 20, 2021 at 2:00 p.m., prevailing Anchorage time.	

NOTICE TO BIDDERS:

Bidders must acknowledge receipt of this addendum prior to the hour and date set for the bid due date by one of the following methods:

- (a) By acknowledging receipt of this addendum on the proposal form submitted.
- (b) By email or telefacsimile which includes a reference to the project and addendum number.

The bid documents require acknowledgment individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may be classified as not being a responsive bid. If, by virtue of this addendum it is desired to modify a bid already submitted, such modification may be made by email or telefacsimile provided such an email or telefacsimile makes reference to this addendum and is received prior to the opening hour and date specified above.

The Bid documents for the above project are amended as follows (All other terms and conditions remain unchanged):

CONTRACT PROVISIONS AND SPECIFICATIONS**Item #1- Design Drawing Revisions:****SHEET 15 DETAIL 2 MOTORIZED VALVE MV-1 LADDER DIAGRAM**

DELETE the (4) normally closed relay contacts currently shown in parallel between terminals L12 and 58. Specifically TPS P1-IB, TPS P2-IB, TPS P3-IB AND TPS P4-IB.

ADD (4) normally closed contacts: TPS P1-2, TPS P2-2, TPS P3-2 AND TPS P4-2 in series between terminals L12 and 58.

SHEET 19 DETAIL 2 MOTORIZED VALVE MV-4 LADDER DIAGRAM

DELETE the (4) normally closed relay contacts currently shown in parallel between terminals L12 and 58. Specifically TPS P5-IB, TPS P6-IB, TPS P7-IB AND TPS P8-IB.

ADD (4) normally closed contacts: TPS P5-2, TPS P6-2, TPS P7-2 AND TPS P8-2 in series between terminals L15 and 64.

QUESTIONS AND ANSWERS

Question: Will there be another pre bid meeting?

Answer: Yes. Another pre bid meeting is scheduled for Friday October 15th, 2021 at 10:30am.

END OF ADDENDUM